



CERTIFICATE OF ANALYSIS

Customer : Atane Design & Construction Consultants
40 Wall Street, 11th Floor
New York, NY 10005

Project ID : Essex County Schools of Technology, Donald M. Payne Tech, 498-544 Market St., Newark, NJ 07107
PAS Project ID : P19-5039

Matrix : Drinking Water
Report Date : 6/27/2019

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P19-5039-01	Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/19 07:45	6/21/19 13:21
P19-5039-02	BS-POE-IN-RH032F	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/19 07:48	6/21/19 13:25
P19-5039-03	BS_KI-IN-024A-St-H	Lead	7.41	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/19 07:55	6/21/19 13:29
P19-5039-04	01-KI-IN-161-ST-D	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/20/19 08:01	6/21/19 13:33

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director