


**LEAD TESTING PROGRAM
STATEMENT OF ASSURANCE
School Year 2018-2019**

County: Essex	
School District, Charter School, Renaissance school project, jointure commission, or other eligible organization as defined in N.J.A.C. 6A:26A-1: Essex County Vocational Technical Schools – Newark Tech Campus	
Address: 91 West Market St., Newark, NJ 07103	
Chief School Administrator (CSA): Dr. James M. Pedersen	Telephone #: 973-412-2077
CSA Email: jpedersen@essextech.org	
Alternate Contact Person: Bernetta Davis	Telephone #: 973-412-2078
Title: Business Administrator	Email: bdavis@essextech.org

1. The school district, charter school, renaissance school, jointure commission, educational services commission, approved private school for students with disabilities acting under contract to provide educational services on behalf of New Jersey public school districts, State-funded early childcare facilities pursuant to N.J.A.C. 6A:13A, and receiving schools as defined by N.J.A.C. 6A:14-7.1(a) (hereinafter collectively referred to as "District"), has reviewed the Amendments to N.J.A.C. 6A:26 requiring immediate testing for lead in drinking water and provides assurance that the development and implementation of a testing program has been completed in accordance with the technical guidelines established by the NJ Department of Environmental Protection as evidenced by our completion of the attached Program Checklist, all notifications of test results were provided consistent with this subchapter, and that alternate drinking water continues to be made available to all students and staff.
2. The District will continue to fully implement the N.J.A.C. 6A:26-12.4 regulations.
3. The District will maintain compliance with all applicable laws, codes, and regulations governing the provision of potable drinking water and testing of drinking water for lead including, but not limited to N.J.A.C. 6A:26-12.4; the Safe Drinking Water Act, N.J.S.A. 58:12A-1 et seq., the rules promulgated pursuant thereto, N.J.A.C. 7:10 and N.J.A.C. 6A:26-6, Planning and Construction Standards for School Facilities.

CERTIFICATION: By signing below, the Chief School Administrator certifies that all statements above are true and correct:

Name Dr. James M. Pedersen Title Superintendent

Signature: 

Date: 6/27/2019

NJ Department of Education

www.nj.gov/education/lead/
leadtesting@doe.state.nj.us



School District Lead Sampling Program Checklist

SCHOOL DISTRICT INFORMATION

District Name: Essex County Vocational Technical Schools

Address: 60 Nelson Place, 1 North

Telephone number: 973-412-2074

Application Signatory:

Note: Any sampling done prior to July 13, 2011 is not eligible for exemption from State Board of Education Special Adopted Amendments N.J.A.C. 6A:26-1.2 and 12.4.


COMPLETION OF INITIAL LEAD SAMPLING AT 4 SCHOOL FACILITIES OUT OF 4 SCHOOL FACILITIES

Fill out the table below for each school facility the School District has completed initial lead sampling. Make as many copies of the following page as necessary.

School Facility Name Newark Tech

Sampling Date(s) Initial Sampling-- April 30, 2017 and Follow-up Sampling-- June 11, 2017

- Yes No Does the District have a signed contract with a New Jersey Certified Drinking Water Laboratory for lead analysis?
- Yes No Is there a Plumbing Profile in accordance with NJDEP technical guidance?
- Yes No Is there a Floor Plan in accordance with NJDEP technical guidance?
- Yes No Were all the drinking water outlets in the school facility (including auxiliary buildings and outside outlets on the school grounds) where a student or staff member has or may have access sampled?
- Yes No Were all the drinking water outlets sampled in the sequence determined by the Floor Plan beginning with the outlet closest to the Point of Entry?
- Yes No Were all samples taken after the water sat undisturbed in pipes for at least 8 hours but no more than 48 hours?
- Yes No Were samples collected in pre-cleaned high density polyethylene (HDPE) 250 ml wide mouth single use rigid sample containers?
- Yes No Were all existing aerators, screens, and filters left in place prior to and during the sampling event?
- Yes No N/A Were all drinking water outlets with a result exceeding the lead action level (15µg/L) taken out of service or permanently remediated?
- Yes No N/A Did all drinking water outlets with a result that exceeded the lead action level (15µg/L) have a follow-up flush sample conducted?
- Yes No Does the District have the Chains of Custody and analytical reports for all of the drinking water outlets sampled?
- Yes No Were test results of all water samples made publicly available at the school facility and on the District's website?
- Yes No N/A If any of the results exceeded the lead action level (15µg/L), was written notification sent to the parent/guardians of all students attending the facility?



Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : HAKS
40 Wall Street, 9th Floor
New York, NY 10005

Project ID : Newark Tech High School, 91 W. Market St. Newark, NJ, 07103
PAS Project ID : P17-S901

Matrix : Drinking Water
Report Date : 10/16/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-5901-01	FIELD BLANK	Lead	ND	ug/L	1	2.00	0.430	15.0 *	SM 3113 B	10/1/17 11:35	10/9/17 13:20
P17-5901-02	01-POE-IN-105-F	Lead	1.06 J	ug/L	1	2.00	0.430	15.0 *	SM 3113 B	10/1/17 11:38	10/9/17 13:24
P17-5901-03	01-HA-BY-105-DW	Lead	10.9	ug/L	1	2.00	0.430	15.0 *	SM 3113 B	10/1/17 11:40	10/9/17 13:40
P17-5901-04	01-OF-BY-125-FP	Lead	65.2	ug/L	10	20.0	4.25	15.0 *	SM 3113 B	10/1/17 11:41	10/9/17 16:28
P17-5901-05	01-MO-IN-125-F	Lead	4.70	ug/L	1	2.00	0.430	15.0 *	SM 3113 B	10/1/17 11:42	10/9/17 15:10
P17-5901-06	01-HA-BY-127-DW	Lead	78.2	ug/L	10	20.0	4.25	15.0 *	SM 3113 B	10/1/17 11:43	10/9/17 16:32
P17-5901-07	03-KI-FP (D)	Lead	4.70	ug/L	1	2.00	0.430	15.0 *	SM 3113 B	10/1/17 11:46	10/9/17 15:19

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director